

EU type examination certificate


EU-Baumusterprüfbescheinigung

CE-0085CS0332

Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EU Gas Appliances Regulation (EU/2016/426) <i>EU-Gasgeräteverordnung (EU/2016/426)</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
Distributor <i>Vertreiber</i>	Bosch Thermotechnik GmbH Junkersstraße 20-24, D-73249 Wernau
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Gas wall hanging condensing boiler with integrated heat exchanger for domestic hot water (DHW)
Model <i>Modell</i>	Bosch Condens GC2200(i)W
Countries of Destination <i>Bestimmungsländer</i>	BG, EE, HU, LT, LV, MD, PL, RO, TR
Test Reports <i>Prüfberichte</i>	supplement test: B 18/08/2767 EU from 30.08.2018 (DBI)
Test Basis <i>Prüfgrundlagen</i>	EU/2016/426 A III B (09.03.2016) DIN EN 15502-1 (01.10.2015) DIN EN 15502-2-1 (01.09.2017) DIN EN 13203-1 (01.12.2015)

Date of Expiry / File No. 24.07.2028 / 18-0671-GEA
Ablaufdatum / AZ

11.09.2018 Rie A-1/2 
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EU Regulation

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EU-Verordnung EU/2016/426.



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data 230 V AC, 50 Hz
Elektrische Daten

Appliance Categories <i>Gerätekatogorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
II2ELwLs3B/P	20,20,13, 37 mbar	PL	
II2H3B/P	20, 30 mbar	EE, LT, LV, RO, TR	
II2H3P	20, 37 mbar	EE, LT, LV, RO, TR	
II2HS3B/P	25, 30 mbar	HU	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
GC2200(i)W 24 C23	nominal heat output: 4,8...24,0 kW heat input (Hi): 4,9...24,5 (DHW: ...25,5) kW	
GC2200W 24 C23; GC2200W 20/25 C23	nominal heat output: 4,8...20,0 kW nominal heat input (Hi): 4,9...20,4 (DHW: ...25,5) kW	
GC2200W 15/25 C23	nominal heat output: 4,8...15,0 kW nominal heat input (Hi): 4,9...15,3 (DHW: ...25,5) kW	

Hints of Utilization /Remarks

Verwendungshinweise / Bemerkungen

flue types: B23, B23P, B33, C13(x), C33(x), C43(x), C53(x), C63(x), C83(x), C93(x) according installation manual 6720886267

Additional proved countries of destination, appliance categories and supply pressures:

BG, MD: II2H3B/P (20, 30 mbar)

MD: II2H3P (20, 30 mbar)

In the NON-EU countries the CE-marking will be accepted as conformity approval if the Gas Appliance Regulation EU/2016/426 is transferred into national law by this countries.