



Bosch Thermoteknik AB
Box 1012
573 28 Tranås
Visitors:
Hjälmarydsvägen 8
Tranås
Tel +46 140-38 43 00
Fax +46 140 178 90
www.bosch.se

3 April 2020

We,
Bosch Thermoteknik AB,

hereby declare that the below listed air-to-water heat pumps reach SCOP value provided in the below table. The SCOP values were calculated based on EN-14825:2013, from test points tested according to EN-14511:2011.

Model name	Ordering number	SCOP	Climate
Compress 6000 AW-5	8738205060	4.65	Average Climate, Low Temperature (35°C)
Compress 6000 AW-7	8738205061	5.16	
Compress 6000 AW-9	8738205062	4.93	
Compress 6000 AW-13	8738205063	4.54	
Compress 6000 AW-17	8738205064	4.85	
Compress 6000 AW-13s	8738206675	4.73	
ODU Split 8	8738206021	4.77	
ODU Split 15s	8738206024	4.36	
ODU Split 11t	8738206025	4.65	
ODU Split 13t	8738206026	4.27	
ODU Split 15t	8738206027	4.27	

Yours sincerely,

Victor Fransson
Bosch Thermoteknik AB