

EG-Baumusterprüfbescheinigung

EC type examination certificate

CE-0085BS0253

Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Gasgeräte-richtlinie (90/396/EWG) <i>EC Gas Appliances Directive (90/396/EEC)</i>
Zertifikathaber <i>owner of certificate</i>	BOSCH ISITMA ÜRÜNLERİ SAN. ve TIC. A.S. Organize Sanayi Bölgesi Org. San Bölgesi, TR-45030 Manisa
Vertreiber <i>distributor</i>	BBT THERMOTECHNIK GMBH Sophienstraße 30-32, D-35576 Wetzlar
Produktart <i>product category</i>	Boilers with flue systems: Condensing combi water heater (3204)
Produktbezeichnung <i>product description</i>	Gas wall hung condensing combi water heater optionally also as condensing water heater for central heating
Modell <i>model</i>	Cerapur smart ZWB/ZSB...-3C 23S
Bestimmungsländer <i>countries of destination</i>	IT, PL
Prüfberichte <i>test reports</i>	type testing: 07/07/0965 from 26.07.2007 (DBI)
Prüfgrundlagen <i>basis of type examination</i>	EU/90/396/EWG (29.06.1990) DIN EN 483 (01.06.2000) DIN EN 483/A2 (01.05.2002) DIN EN 483/A4 (draft 01.06.2005) DIN EN 625 (01.10.1995) DIN EN 13203-1 (01.11.2006)
Aktenzeichen <i>file number</i>	07-0462-GEE



31.10.2007 Rje A-1/2

Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der Europäischen Kommission offiziell registrierte Stelle für die Konformitätsbewertung von Gasgeräten

DVGW CERT GmbH - notified by the government of the Federal Republic of Germany and officially registered by the European Commission for conformity assessment of gas appliances

ZLS

DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888
Telefax: +49 228 91 88-993
eMail: info@dvgw-cert.com

ZLS-ZE-527/07

Elektrische Daten: 230 V AC, 50 Hz, IPX4D
electrical data

Geräte-kategorien <i>appliance categories</i>	Versorgungsdrücke <i>supply pressures</i>	Bestimmungsländer <i>countries of destination</i>	Bemerkungen <i>remarks</i>
I12E LwLs3B/P	20,20,13, 28-30 mbar	PL	
I12HM3B/P	20, 30 mbar	IT	
I12HM3P	20, 37 mbar	IT	

Typ <i>type</i>	Technische Daten <i>technical data</i>	Bemerkungen <i>remarks</i>
ZSB 14-3C 23S	heat output: 3,28...12,71 kW heat input (Hi): 3,4...13,3 kW	
ZSB 22-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 kW	
ZWB 24-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 (Trinkwasser: ...24,6) kW	
ZWB 28-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 (Trinkwasser: ...28,0) kW	

Ausführungsvariante <i>type variation</i>	Erläuterungen <i>explanations</i>
ZWB...	condensing combi water heater
ZSB...	condensing water heater for central heating

Verwendungshinweise / Bemerkungen
hints of utilization / remarks

Flue types B23, B33, C13, C13x, C33, C33x, C33S, C43, C43x, C53, C63, C63x, C83 und C83x: according to installation manuel No. 6 720 614 147

EG-Baumusterprüfbescheinigung

EC type examination certificate

CE-0085BS0253

Produkt-Identnummer
product identification no.

Anwendungsbereich <i>field of application</i>	EG-Wirkungsgradrichtlinie (92/42/EWG) <i>EC Efficiency Directive (92/42/EEC)</i>
Zertifikatinhaber <i>owner of certificate</i>	BOSCH ISITMA ÜRÜNLERI SAN. ve TIC. A.S. Organize Sanayi Bölgesi Org. San Bölgesi, TR-45030 Manisa
Vertreiber <i>distributor</i>	BBT THERMOTECHNIK GMBH Sophienstraße 30-32, D-35576 Wetzlar
Produktart <i>product category</i>	Boilers with flue systems: Condensing combi water heater (3204)
Produktbezeichnung <i>product description</i>	Gas wall hung condensing combi water heater optionally also as condensing water heater for central heating
Modell <i>model</i>	Cerapur smart ZWB/ZSB...-3C 23S
Heizkesseltyp <i>type of boiler</i>	condensing boiler
Prüfberichte <i>test reports</i>	type testing: 07/07/0965 from 26.07.2007 (DBI)
Prüfgrundlagen <i>basis of type examination</i>	EU/92/42 (21.05.1992)
Aktenzeichen <i>file number</i>	07-0462-GWE

31.10.2007 Rie A-1/2

Datum, Bearbeiter, Blatt/Letter der Zertifizierungsstelle
date, issued by, sheet, head of certification body

DVGW CERT GmbH - von der Deutschen Bundesregierung benannte und von der
EU-Kommission offiziell registrierte Stelle für die Konformitätsbewertung von
Heizkessel-Wirkungsgraden

DVGW CERT GmbH - notified by the government of the Federal Republic of
Germany and officially registered by the EC Commission for conformity
assessment of heating boiler efficiencies



DVGW CERT GmbH
Josef-Wirmer-Straße 1-3
53123 Bonn

Telefon: +49 228 91 88-888

Telefax: +49 228 91 88-993

eMail: info@dvgw-cert.com

JP42 9.2-03342/2007

Typ type	Technische Daten technical data	Energieeffizienzkennz. energy labelling
ZSB 14-3C 23S	heat output: 3,28...12,71 kW heat input (Hi): 3,4...13,3 kW	****
ZSB 22-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 kW	****
ZWB 24-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 (Trinkwasser: ...24,6) kW	****
ZWB 28-3C 23S	heat output: 7,38...20,24 kW heat input (Hi): 7,5...20,8 (Trinkwasser: ...28,0) kW	****

Verwendungshinweise / Bemerkungen

hints of utilization / remarks

The energy labelling can be used according to the actual regulations of the country of destination for the individual types. The above listed model was certified under the Product-Identnumber CE-0085BS0253 according to the Gas Appliance Directive (90/396/EEC).